

C-0501



Product Service

# Attestation of Conformity

No. N8 10 05 73900 001

Holder of Certificate: **Zhejiang Chint Electrics Co., Ltd.**

Chint Industrial Zone, North Baixiang  
325603 Yueqing, Wenzhou, Zhejiang  
PEOPLE'S REPUBLIC OF CHINA

Product: **Low voltage switchgear combination  
Automatic transfer switching equipment**

Model(s): **NZ7-63S, NZ7-63H, NZ7-100S, NZ7-100H, NZ7-100R,  
NZ7-225S, NZ7-225H, NZ7-225R, NZ7-400S, NZ7-400H,  
NZ7-400R, NZ7-630S, NZ7-630H, NZ7-630R**

Parameters:

Rated voltage:	400V~
Rated frequency:	50Hz
Rated current:	
	le=6A, 10A, 16A, 20A, 25A, 32A, 40A, 50A, 63A (NZ7-63S, NZ7-63H)
	le=16A, 20A, 25A, 32A, 40A, 50A, 63A, 80A, 100A (NZ7-100S, NZ7-100H, NZ7-100R)
	le=100A, 125A, 160A, 180A, 200A, 225A (NZ7-225S, NZ7-225H, NZ7-225R)
	le=225A, 250A, 315A, 350A, 400A (NZ7-400S, NZ7-400H, NZ7-400R)
	le=400A, 500A, 630A (NZ7-630S, NZ7-630H, NZ7-630R)
Short-circuit characteristic:	
	Icn=25kA(NZ7-63S, only for 3P), 50kA(NZ7-63H)
	Icn=35kA(NZ7-100S), 50kA(NZ7-100H), 85kA(NZ7-100R)
	Icn=35kA(NZ7-225S), 50kA(NZ7-225H), 85kA(NZ7-225R)
	Icn=50kA(NZ7-400S), 65kA(NZ7-400H), 100kA(NZ7-400R)
	Icn=50kA(NZ7-630S), 65kA(NZ7-630H), 100kA(NZ7-630R)
Poles No.:	3P, 4P
Degree of protection:	IP30
Product information:	Class CB, Utilization category.: AC-33B

Tested according to: EN 60947-6-1:2005

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2006/95/EC relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive. It refers only to the particular sample submitted for testing and certification. See also notes overleaf.

Test report no.: 704100995402-00

Date, 2010-05-06 ( Roy Yongjun Xue )

**CE** After preparation of the necessary technical documentation as well as the EC conformity declaration the required CE marking can be affixed on the product. Other relevant directives have to be observed.

